Autonics

TEMPERATURE CONTROLLER TC3YT SERIES





Thank you very much for selecting Autonics products. For your safety, please read the following before using.

Caution for your safety

*Please keep these instructions and review them before using this unit.

*Please observe the cautions that follow;

 Marning Serious injury may result if instructions are not followed. ⚠ Caution Product may be damaged, or injury may result if instructions are not followed.

★The following is an explanation of the symbols used in the operation manual.

Δ caution:Injury or danger may occur under special conditions.

- I. In case of using this unit with machineries (Nuclear power control, medical equipment, vehicle, train, airplane, combustion apparatus, entertainment or safety device etc), it requires installing fail-safe device, or contact us for information on type required.
- ay result in serious damage, fire or human injury 2. It must be mounted on Panel.
- It may give an electric shock.

 3. Do not connect terminals when it is power on.
- 4. Before connecting power, check the terminal number.
- It may cause a fire.

 5. Do not disassemble and modify this unit, when it requires.
- If needs, please contact us.
 It may give an electric shock and cause a fire.

- 1. This unit shall not be used outdoors.
- It might shorten the life cycle of the product or give an electric shock.

 2. For wire connection, No.12~28AWG should be used and screw bolt on terminal block with 0.3N • m to 0.4N • m strength.
 It may result in malfunction or fire due to contact failure.
- It may result in final unition of the due to contact randle.

 3. Please observe specification rating.

 It might shorten the life cycle of the product and cause a fire.

 4. Do not use the load beyond rated switching capacity of Relay contact.
- It may cause insulation failure, contact melt, contact failure, relay broken, fire etc.


 5. In cleaning the unit, do not use water or an oil-based detergent

 It might cause on clearly sheet in the first three contacts.
- It might cause an electric shock or fire that will result in damage to the product.

 6. Do not use this unit at place where there are flammable or explosive gas, humidity,
- direct ray the sun, radiant heat, vibration, impact etc.
- 7. Do not inflow dust or wire dregs into inside of this unit.
- n may cause a fire or mechanical trouble.


 8. Before connecting wires, check the terminal polarity. It may cause a fire or explosion.

Front panel identification



Dimensions

- 1 PV(Process value) display(Red) 2 Minus display(Red)
- 3 Controlling a set value(MD, UP, DOWN)4 Display an operation of control output(Red)
- 5 Display a deviation between PV(Process value) and SV(Set value) : ▲. ▼(Red) /
- 6 PV(Process value) °C/°F unit display(Yellow)




Connections COM 8 9 10 11 *250VAC 3/16A 1c ♣⊖ ੈ ▲

**TC3YT-B4R3: 250VAC 3A TC3YT-B4R16: 250VAC 16A SOURCE 100-240VAC 4VA 50/60Hz RTD +L___ - TC(*NTC:Option)


Set and change a SV ODisplay for power ON

For power ON, it displays current temperature after temperature sensor and the type of control output flicker twice(every 1 sec). In case of error, Error signal flickers instead of current temperature.



○Check and set a SV(Setting Value)

- •SV can be checked and set on operation mode
- Press MD key on operation mode. ①Operation mode(display a current temperature)



①PV is displayed on operation mode, ②Press MD key, the SV is indicated after "5" is flickering 2 times.

③In case of checking the SV only, after check it pressing MD key, then it returned to the drive mode.

 \P In case of changing and setting the SV, set it with \blacksquare , \blacktriangledown keys. If you press \blacksquare , \blacktriangledown keys continuously, the SV is increased/decreased with high-speed.

(a) If press MD key after setting, the set value is saved and the mode returns to operation.

*When there is no input for 1 min. for setting operation, it returns to operation mode and the parameter set value is not changed the prior value is saved.

Input specification and range

Input		Using range		
Sensor	Parameter	°C	°F	
K	FCB	0 ~ 999	32 ~ 999	
J	JI [0 ~ 400	32 ~ 752	
Pt H	PŁH	0 ~ 400	32 ~ 752	
Pt L	PŁ.L	−99 ~ 199	-146 ~ 390	

- *A temperature sensor converts temperature into electrical signal so that a controller can do ON/OFF the control output

discontinued without notice.

- *The setting is available with the using range.

 *The setting is available with the using range.

 *The setting range of the SV is limited within the using temperature range.

 *Using temperature: It can be set as '\(\mathcal{C}\), 'F are displayed on the front side.

 *The above specifications are subject to change and some models may be


Ordering information

<u>TC 3</u>	<u>Y</u>	$\underline{T} - \underline{B} \underline{4} \underline{R} \underline{3}$
1 2	3	4 5 6 7 8
① Item	TC	Temperature Controller
② Digit	3	3 Digit
③ Size	Υ	DIN W72×H36mm
Setting type	Т	Touch S/W single setting type
Control mode	В	ON/OFF and proportional control(common use)
Power supply	4	100-240VAC 50/60Hz
Control output	R	Relay output
Polov conscity		250VAC 3A 1c
Relay capacity	16	250VAC 16A 1c

Specifications

Model Power sup Allowable		TC3YT-B4R3			
			TC3YT-B4R16		
Allowable	- 1- 2	100-240VAC 50/60Hz			
	voltage range	0.0000000000000000000000000000000000000			
Power cor	nsumption	Approx. 4VA			
Display method		7Segment Red LED Display [Deviation "■" signal(Green), unit display(Yellow)]			
Character size		W7.4 × H15mm			
Input type(∗)		TC:K(CA), J(IC), RTD: Pt100Ω(DIN)			
Control output		Relay output 250VAC 3A 1c	Relay output 250VAC 16A 1c		
Control method		ON/OFF and proportional control (common use)			
Hysteresis		1 ~ 100℃			
Proportional band		0 ~ 100%			
Offset cor	rrection	0 ~ 100%			
Control pe	eriod	1 ~ 120sec			
Display method		±1digit with a bigger one of ±0.5% of PV or ±1℃			
Setting type		Setting by front push buttons			
Sampling period		500ms			
Dielectric	strength	2000VAC 60Hz for 1 minute(between external terminal and case)			
Vibration		0.75mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 1 hours			
Relay	Mechanical	Min.10,000,000 times			
	Malfunction	Min.100,000 times (250VAC 3A resistive load)	Min.100,000 times (250VAC 16A resistive load)		
Insulation resistance		Min. 100MΩ (at 500VDC)			
Noise stre	ength	±2kV R-phase and S-phase (pulse width 1 μs)			
Memory re	etention	Approx. 10 years (When using non-volatile semiconductor memory type)			
Ambient t	emperature	-10 ~ 50 ℃ (at non-freezing status)			
Storage te	emperature	-20 ~ 60°C(at non-freezing status)			
Ambient h	numidity	35 ~ 85%RH			
Protection	n	IP65			
Weight		Approx. 99g	Approx. 103g		
*NTC sensor input is optional.					


Flow chart for first setting group



- ●In operation mode, if press MD key for 2 sec., it enters setting group 1.

 At the beginning of MD key input, **5** u signal is displayed. And then **P** signal, the first mode of group 1 is displayed for 2~3 sec. It enters the first mode of group 1 for finishing
- Parameter will be displayed when entering setting mode.
- Press MD key one time, parameter move to the next. Moreover for changing a set value, press key. (Set value is flickering every one sec.)
- •Press a MD key after changing a set value or for the statue of setting change, the setting value is saved and the parameter is changed to the next.
- •In any moment during the setting operation, if press MD key for 3 sec., the changed value is saved and the mode is changed to operation mode.
- •When there is no input for 1 min. for setting operation, it returns to operation mode
- and the parameter set value is not changed the prior value is saved.
- •When **P** is not "0", [**H45**] parameter is not displayed.
 •When **P** is "0", ON/OFF control, [**£**] and [**r5£**] parameter is not displayed.
- ₩When it is entered to the setting mode for all cases, applicable parameters will be

Flow chart for second setting group



•In operation mode, if press MD key for 4 sec., it enters setting group 2 At the beginning of MD key input, 5 u signal is displayed. And then P signal, the first mode of group 1, is displayed for $2\sim3$ sec. for the moment of 4 sec past, $I \cap L$, the first mode of setting group 2, is displayed. It enters the first mode of group 2 for finishing

Parameter will be displayed when entering setting mode.

Press MD key one time, parameter move to the next. Moreover for changing a set

press MD key.

value, press Akey. (Set value is flickering every one sec.)

• Press a MD key after changing a set value or for the statue of setting change, the

setting value is saved and the parameter is changed to the next.

In any moment during the setting operation, if press MD key for 3 sec., the changed

• When there is no input for 1 min. for setting operation, it returns to operation mode. and the parameter set value is not changed the prior value is saved.

*When it is entered to the setting mode for all cases, applicable parameters are displayed.

₩When the unit of the using temperature is changed, the SV is changed as 0°C

Functions

○Input correction [In.b]

- Input correction [IA-B]
 Input revise corrects the deviation, occurred from temperature sensor such as thermocouples, RTD, Analogue sensor etc.
 There are grades for temperature sensor and high accuracy one is a high price, normal products are usually used. Check the deviation of every thermo sensor precisely
- The state of the state of
- because if measured deviation value is not correct, displayed temperature will be too high or too low. •Setting range: $-49 \sim 50 \, ^{\circ}$ (Factory default: $0 \, ^{\circ}$) Ex)When even though current temperature is $80 \, ^{\circ}$, display value is $78 \, ^{\circ}$, input correction

value should be 2 to display 80℃.

- ○Hysteresis [HY5] In the ON/OFF control, the ON/OFF interval of the output is required, this interval is hysteresis. When this interval is too narrow, it causes hunting such as chattering by The state of the state of
- Because the hunting is generated by combined cause, **Hy5** set value, response spec, sensor position, etc., it is not regular. To minimize it, proper **Hy5** value, the capacity and characteristic of heater, and response and position of sensor need to be considered.

 Setting range: 1 ~ 100° (Factory default: 2°C)

- Proportional band[P]
 ●If current temperature(PV) is within the proportional control, it controls the ratio of ON and OFF during proportional control. At this moment the term of proportional control
- for set value is called proportional band •Setting range : 0 ~ 100%(Factory default : 0%)
- Control period (Proportional control)[E]
 When output the control value by using relay and SSR on the proportional control, it repeats ON for set time and OFF.
- •The set time is called proportional control period. •Setting range: 1 ~ 120s(Factory default: 10s)
- Setting range

- Hysteresis / proportional band / proportional period is set on parameter

 Setting range of hysteresis [H 5]: 1 ~ 100°C

 Setting range of proportional band [P]: 0 ~ 100%

 Setting range of control period [£]: 1 ~ 120sec


 ON/OFF control → Proportional control conversion: When P is 0%, it is ON/OFF control: if there is a value for P, is proportional control. The parameter of hysteresis [H 5] appears when [P], proportional band, is 0%.

 Offset correction / Manual reset [-5£]

- When use the proportional control, even when it is stable statue, deviation can occur because of heat capacity and heater capacity. It is called offset.

 Offset is set on the parameter of inner manual reset [-5½].

 Offset correction is used only for proportional control. (Not for [P]=0%). Therefore if proportional band [P] is set as 0%, manual reset parameter [-5½] is not shown.
- Setting range: 0~100% (Factory default: 50%)
 Set a value as 50% when PV is equal to SV. After control is stable, if measured temperature is lower than SV, set value is over than 50%, otherwise lower than 50%.



Control mode switch

• User can choose ON/OFF and proportional control.
• ON/OFF control − Proportional control conversion:
When P is 0%, it is ON/OFF control: if there is a value for P, is proportional control.
• Factory default: ON/OFF control(P:0%)

The conversion of temperature unit(℃ / °F)[Unb] •By choosing ℂ or □F on temperature unit setting parameter, [Unb] conversion is available.

- ●After choosing a temperature unit, LED is ON.
 ●Factory default: □[
 ○Cooling / Heating operation

•Generally there are two ways to control temperature, one(heat-function) is to heat when PV is getting down(heater). The other(cool-function) is to cool when PV is getting

high refrigerator)

Error display

- •Setting range: HEt(Heat) / Col(Cool) (factory default : HEt) Display a PV deviation
- It displays the deviation between the PC and the SV.
 When the PV is higher than the SV(PV > SV+2℃), △ is lighted.
 When the PV is lower than the SV(PV < SV-2℃), ▽ is lighted.
 When the deviation of the PV is within ±2℃, □ is lighted.
- OHigh/low limit setting for using temperature

- Set a high/low limit of temperature and the set range is within using range.
 •If setting a high—limit of temperature on [HSE], it is a high—limit SV
 •If setting a low—limit of temperature on [LSE], it is a low—limit SV.
 •L.SC \leq SV \leq H.SC. In case of L.SC= SV = H.SC, the output is OFF.
 •If change L.SC and H.SC, the using range and proportional band also are changed.
- ullet If Error occurs during the operation, error signal flickers every one sec.
- Description When the input sensor is not connected or its wire is cut. (Normal operation after connecting a sensor) **LLL** When the measured input temperature is lower than input range of the sensor.
- HHH When the measured input temperature is higher than input range of the sensor.

 •When error [□Pn] / [LLL] / [HHH] occur

 After the causes of error is solved, it operates normally.

 •The priority of 'Error' display: □Pn → HHH, LLL

- Output setting for error[aEr]
 For error, the statue of output is set by [aEr] of setting group 2.

 •For setting OFF: Output is always OFF for error.
- ●For setting ON: Output is always ON for error. ●Factory default: OFF DLock setting[Lo[]
- •This function limits the change of parameters on each setting group. It can be set setting group 2. For setting [Lf I], changing the parameter, "Setting group 2", is not available. •For setting [Lf I], changing the parameter, "Setting group 1 + Setting group 2", is
- not available.

 For setting [LE3], changing the parameter, "Setting group 1 + Setting group 2 + SV
- setting parameter", is not available.

 •For setting [•FF], Lock off for all setting group

■ Factory default

First setting group

ı	r arameter	Description	Setting range	Offic	ractory derault	
ı	P	Proportional band	0 ~ 100	%	0	
ı	Ł	The period of proportional control	1 ~ 120	sec	10	
l	r S Ł	The correction value of offset for proportional control	0 ~ 100	%	50	
ı	H42	Hysteresis for ON/OFF control	2 ~ 100	°C	2	
ı	l n.b	Input correction value	-30 ~ 30	°C	0	
•Second setting group						

Second setting group						
Parameter	Description	Setting range	Unit	Factory defaul		
1 n.E	Temperature sensor	ECH, JI C, PEH, PEL	-	JI E		
H.5 C	High-limit value of using temperature	See "Input specifications	°C	400		
L.SC	Low-limit value of using temperature	and range"	°C	0		
o.F Ł	Cooling/Heating operation	HEŁ ←→ [oL	_	HEF		
o.Er	Output for error	on◆→oFF	-	oFF		
Unt	Temperature unit	0[←→ 0F	_	٥٥		
LoC	Lock	oFF, LC 1, LC2, LC3	_	oFF		

LoC Lock Caution for using

Installation environment Ilt shall be used indoor.

1. Installation environment
Oil shall be used indoor.
②Neltitude Max. 2000m.
③Installation Category II.
2. Please install power switch or circuit—breaker in order to cut power supply off.
3. The switch or circuit—breakers should be installed near by users.
4. Do not use this product as Volt—meter or Ampere—meter, this is a temperature controller.
5. Be sure to use compensating wire when extends wire from controller to thermocouple, otherwise the temperature deviation will be occurred at the part where wires are connected to

6. In case of using RTD sensor, 3wire type must be used. If you need to extend the line, 3wires

b. In case of using RTID sensor, 3wire type must be used. If you need to extend the line, 3wires must be used with the same thickness as the line. It might cause the deviation of temperature if the resistance of line is different.
7. In case of making power line and input signal line closely, line filter for noise protection should be installed at power line and input signal line should be shielded.
8. Keep away from the high frequency instruments. (High frequency welding machine & sewing machine, large capacity SCR controller)

*It may cause malfunction if above instructions are not followed.

Main products

Autonics Corporation http://www.autonics.com Satisfiable Partner For Factory Automation

OVERSEAS SALES #402-404, Bucheon Techno Park, 655, Pyeongcheo #402-404, Bucheon, Gyeonggi-do, Korea TEL: 82-32-610-2730 / FAX: 82-32-329-0728 E-mail: sales@autonics.com

EP-KE-03-0310A