Autonics

TEMPERATURE INDICATOR T3NI/T4YI/T4WI/T4WM SERIES



Thank you very much for selecting Autonics products. For your safety, please read the following before using.

Caution for your safety

*Please keep "Caution for your safety" to avoid accidents or damages as using it correctly.

*The meaning of 'Warning' and 'Caution' is as follows;

Warning In case a serious injury or dead may be occurred.

*The meaning of the mark on the product and manual is as follows; ▲ is a caution mark for danger in special condition.

⚠ Warning

- 1. Please use it with double safety devices when it is used at the equipments which may cause damages to human life or assets. (Ex:Nuclear power, Medical equipment, Vehicle, Train, Air plane, Combustion apparatus, Entertainment or Safety device etc.) It may cause a fire, human life or assets.
- 2. This equipment must be mounted on panel.

It may give an electric shock.

- 3. Do not repair or checkup when power on.
- It may give an electric shock.
- 4. Do not disassemble and modify, when it requires. If needs, please contact us.

It may give an electric shock and cause a fire.

5. Please check the terminal No. when connect.

It may cause a fire

6. Lithium battery is used for memory retention in T4WM, therefore do not disassemble or burn it.

It may cause a fire.

7. This product is a combined use of 110/220VAC, please check the terminal when connect.

It may cause a fire

⚠ Caution

- 1. This equipment shall not be used outdoors.
- It might shorten the life cycle of the product or give an electric shock
- 2. When wire connection, No. 20AWG(0.50mm²) should be used and screw bolt on terminal block with 0.74N · m to 0.90N · m strength. It may result in malfunction or fire due to contact failure.
- 3. Please observe specification rating.

It might shorten the life cycle of the product and cause a fire.

- 4. In cleaning the unit, do not use water or an oil-based detergent. It might cause an electric shock or fire that will result in damage to this product
- 5. Do not use this unit at place where there are flammable or explosive gas, humidity, direct ray of the sun, radiant heat, vibration, impact etc.

It may cause a fire or explosion

6. Do not inflow dust or wire dregs into inside of this unit.


It may cause a fire or mechanical trouble


7. Please wire properly after checking the polarity of terminals when connect thermocouples.

It may cause a fire or explosion.

* The above specifications are subject to change and some models may be discontinued without notice

Ordering information





Specifications

Model

Sensor

input type

scale

range

(°C)

1200

1000

800 Standard 600

400

200

100

-100

Model		T3NI	T4YI	T4WI	T4WM	
Power supply		12-24VDC	100-240VAC 50/60Hz	110/220VAC 50/60Hz		
Allowable operating voltage		90 to 110% of rated voltage				
Power consumption		2W	3VA			
Display method		7 Segment LED Display				
Display accuracy		F • S ±0.3% rdg ±1digit	F•S ±0.5% rdg ±1digit			
Input sensor		RTD: Pt100Ω	Thermocouples : K(CA), J(IC), Pt100Ω			
Input line resistance		RTD:Max. 5Ω per a wire	Thermocouples : Max. 10Ω RTD : Max. 5Ω per a wire			
Available sensor quantity					Thermocouple: Max. 5pcs RTD:Max. 5pcs	
Insulation resistance		Min. 100MΩ (at 500VDC)				
Dielectric strength		2000VAC 50/60Hz for 1 minute				
Noise strength		± 2 kV the square wave noise(pulse width:1 μ s) by the noise simulator				
		±500V	±1kV			
Vibra -tion	Mechanical	0.75mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 1 hour				
	Malfunction	0.5mm amplitude at frequency of 10 to 55Hz in each of X, Y, Z directions for 10 minutes				
Shock	Mechanical	300m/s² (Approx. 30G) 3 times at X, Y, Z direction				
	Malfunction	100m/s² (Approx. 10G) 3 times at X, Y, Z direction				
Ambient temperature		-10 to 50℃(at non-freezing status)				
Storage temperature		-25 to 65℃(at non-freezing status)□				
Ambient humidity		35 to 85%RH				
Weight		Approx. 34g	Approx. 170g Approx. 322g			

Temperature range for each sensor

RTD

Pt100Ω

99.9℃

-99.9℃

399℃

T4YI / T4WI / T4WM

Thermocouples

J(IC) K(CA)

500℃

1200℃

RTD

Pt100Ω


199.9℃


-99.9°C

399℃


Connection

Dimensions






Parts name(T4WM)




- ①: Auto mode indication(LED ON:Auto selection, LED OFF:Manual selection) 23456: Position indication-Indicating the temperature value for position of each sensor(LED ON)
- ①: Auto Time adjuster(1 to 10sec)
- (8): Selection switch
- 9: PV(Display)

■ 5 Point indicator(T4WM)


•How to select the auto mode and manual mode



Manual selection: Touch the select switch



•Auto selection: Display value for each sensor is changed automatically




*CK: Automatic time adjustment Selection of input sensor by inner DIP switch

Sensor Switching	2	3	4	5
SW	3 2 1 ON OFF	3 2 1 ON OFF	3 2 1 ON OFF	3 2 1 ON OFF

Caution for using

- 1. Installation environment
- 1 It shall be used indoor
- ②Altitude Max. 2000m
- ③Pollution Degree 2
- ④Installation Category II
- 2. Please use the terminal(M3.5, Max.7.2mm) when connect the AC power source



- 4. Please install power switch or circuit-breaker in order to cut power supply
- 5. The switch or circuit-breaker should be installed near by users.
- 6. Do not use this product as Volt-meter or Ampere-meter, this is a temperature
- 7. Be sure to use compensating wire when extends wire from controller, otherwise the temperature deviation will be occurred at the part where wires are connected each other.
- 8. In case of using RTD sensor, 3wires type must be used.
- If it needs to extend the line, 3wires must be used with the same thickness as the line. It might cause the deviation of temperature if the resistance of line is different.
- 9. In case of making power line and input signal line close, line filter for noise protection should be installed at power line and input signal line should be shielded.
- 10. Keep away from the high frequency instruments. (High frequency welding machine & sewing machine, big capacitive SCR controller)

*It may cause malfunction if above instructions are not followed.

Main products



■ Control switches/Lamps/Buzzers

I/O Terminal Blocks & Cables Stepper motors/drivers/motion controllers

Graphic/Logic panels

■ Laser marking system(Fiber, CO₂, Nd:YAG)

Satisfiable Partner For Factory Automation ■ HEAD QUARTERS:

18, Bansong-ro 513beon-gil, Haeundae-gu, Busan, Korea

■ OVERSEAS SALES:

#402-404, Bucheon Techno Park, 655, Pyeongcheon-ro,
Wommi-gu, Bucheon, Gyeonggi-do, Korea

TEL: 82-32-510-2730 / FAX: 82-32-329-0728

■ E-mail: sales@autonics.com

Autonics Corporation

FP-KF-03-0040F